



Company

Certificate

(Temporary Structures)

Place and Name of the Event:

.....

Inspected Structure :

.....

.....
HEREBY WE CONFIRM THE INSPECTION OF THE ELECTRICAL INSTALLATIONS ACCORDING TO THE FOLLOWING POINTS

1. Electrical Installations:

a) All Electrical Installations

including mobile power consuming equipment are checked according to the standard

ÖVE/ÖNORM E 8001-6-61: 2001

„ construction of electrical equipment with a nominal voltage up to ~1000 V and =1500 V; part 6-61: inspection –initial inspection is o.k. without any defects .

The electrical equipmentcorresponds to the guideline ONR 151060- „Event Sites“ ,

b) The whole electrical installation is equipped with an easy reachable off switch

The main switch is marked with a sign.

c) All wiring inside of the event structure is covered stumbling safe or 3,0m above ground.

d) All wiring outside of the event structure is covered stumbling safe , buried in the ground or 3,0m above ground. If in an area with vehicle traffic it has to be 5,5m above ground

2. Safety Lighting:

The event structure is equipped with safety lighting according to the standards ÖVE/ÖNORM E 8002-8 „Temporary Constructions, sale sites, exhibition sites or catering sites“ and ÖVE/ÖNORMEN E 8002-1,2 and 3 .

Emergency exit lighting and signs are switched on at every point.

3. Lightning protection:

Lightning protection must accord to OVE-guideline R 6-1, issue 01.02.2011. It has to be documented according OVE-guideline R 6-1, part 7 .

Notes:

Date:

Certified by: